

ATTENTION

Kidde has recalled certain combination Smoke/CO Alarms due to alarm failure.

Description of Recall:

Product: Kidde NightHawk talking combo smoke/CO alarm

Model Number: KN-COSM-IB

Manufacture Dates: June 1, 2004 through December 31, 2010

The alarms are hard-wired into the home's electric power and has a compartment on the back for a 9V battery for backup. The device is white, round and measures about 5-6" in diameter. "Kidde" is engraved on the front of the alarm. The Kidde model number and manufacture dates are printed on a label on the back of the alarm.

Remedy:

Immediately stop using the recalled alarms and contact Kidde directly for a free replacement alarm, based on the date of manufacture or a discount on a new alarm.

Kidde Contact Info:

Toll-free at 855-239-0490 (8:00am - 5:00pm ET, Mon-Fri). Online at www.kidde.com and click on "Product Safety Notice."

These alarms were sold at electrical distributors and home centers nationwide and online at Amazon.com from June 2004 through December 2010 for a cost of \$40 - \$60.

Recall Date: November 10, 2016

Recall Number: 17-031

For further information, please contact the Clementon Bureau of Fire Safety at 856-783-0284, Ext. 123 or visit the Fire Safety Office on Wednesday nights, 5:30pm - 8:00pm.


Front of Unit



Front of Unit
w/ Wire Connectors



Back of Unit



ATTENTION

Kidde has recalled Fire Extinguishers with plastic handles due to Failure to Discharge and Nozzle Detachment

Description of Recall:

This recall involves two styles of Kidde fire extinguishers: plastic handle fire extinguishers and pushbutton Pindicator fire extinguishers.

Plastic Handle Fire Extinguishers: The recall involves 134 models manufactured between January 1, 1973 and August 15, 2017, including models that were previously recalled in March 2009 and February 2015. The extinguishers were sold in red, white and silver, and are either ABC- or BC rated. The model number is printed on the fire extinguisher label. For units produced in 2007 and beyond, the date of manufacture is a 10-digit date code printed on the side of the cylinder, near the bottom. Digits five through nine represent the day and year of manufacture in DDDYY format. Date codes for recalled models from January 2 2012 through August 15, 2017 are 00212 through 22717. For units produced before 2007, a date code is not printed on the fire extinguisher.

Push-button Pindicator Fire Extinguishers: The recall involves 8 models of Kidde Pindicator fire extinguishers manufactured between August 11, 1995 and September 22, 2017. The no-gauge push-button extinguishers were sold in red and white, and with a red or black nozzle. These models were sold primarily for kitchen and personal watercraft applications.

Hazards:

The fire extinguishers can become clogged or require excessive force to discharge and can fail to activate during a fire emergency. In addition, the nozzle can detach with enough force to pose an impact hazard.

Remedy:

Immediately contact Kidde to request a free replacement and for instructions on returning the recalled unit. NOTE: this recall includes fire extinguisher models that were previously recalled in March, 2009 and February, 2015. Kidde branded fire extinguishers included in these previously announced recalls should also be replaced.

Recall information for fire extinguishers used in RVs and motor vehicles can be found at www.NHTSA.gov.

Kidde Contact Info:

Toll-free at 855-271-0773 (8:30am - 5:00pm ET, Mon-Fri and 9:00am - 3PM ET, Sat-Sun), or online at www.kidde.com and click on "Product Safety Recall."

Recall Date: November 2, 2017

Recall Number: 18-022

For further information, please contact the Clementon Bureau of Fire Safety at 856-783-0284, Ext. 123 or visit the Fire Safety Office on Wednesday nights, 5:30pm - 8:00pm.